



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/12
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 820

Dated: 11/12/2024

To

The Chairman,
Excel Public School (A Unit of Excel Foundation),
B-381/9, Om Nagar,
Badarpur New Delhi-44.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Excel Public School (A Unit of Excel Foundation) located at B-381/9, Om Nagar, Badarpur New Delhi-44..

Sir,

With reference to the letter bearing outdoor diary no. 9202 dated 19.11.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.12.2024 in the presence of Mr. Manoj Kumar (Manager) and it was observed that the school building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. 2 nos. of staircases 1.50 meters width each has not been provided.
3. First aid hose reel has not been provided at each floor.
4. Fire pump of 450 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
6. Exit signage has not been adequate.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)
Director
Delhi Fire Service

06/12/24 e

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.