



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 824

Dated: 13 / 12 / 2024

To

The Principal
Govt. Sarvodaya Kanya Vidyalaya,
At Malka Ganj, Delhi-110007.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Sarvodaya Kanya Vidyalaya (School ID. No-1207035) located at Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter No. SKV/MK/1273 dated 21.11.2024 received in this department vide outdoor dairy no.9435 dated: 22.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 New blocks, ground & 03 upper floors each. At the time of inspection Mr. R.S. Bansal (Estate Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional.
2. Terrace level fire pump capacity of 450lpm each block is provided but not functional.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

etc

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

11/12