



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75
आजादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / CGHS/2024/ 673

Dated: 16 /12 /2024

To,

The Dy. Director (L&I) Bldg.,
Delhi Development Authority,
Vikas Sadan, INA,
New Delh-110023.

Sub: Online building plans from fire safety point of view belonging to Hahnemann Enclave CGHS Ltd. at Plot No. 40, Sector-6, Road / street 30, Dwarka, Phase-I, New Delhi – 110075 for addition/alteration.

Sir,

Please refer your online file No. DW6/0089/2023 dated 21.11.2024 on the subject cited above. In this connection it is to inform you that the officer concerned of Delhi Fire Service inspected the aforesaid CGHS and noticed following deficiencies:

1. Width of both staircases of both the Highrise Blocks is 1 m & 120 cm.
2. The width of internal road is varied from 5.5 m to 6.0 m.

Therefore, the proposal is rejected.

Yours faithfully

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

 