

C18



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/ 816

Dated: 11/12/2024

To

The Principal  
M.C. Primary Co-ed School,  
Bhalaswa Dairy, Delhi-1100042.

**Sub:** Regarding issuance of fire safety certificate in r/o M.C. Primary Co-ed School (School ID No-1253014) located at J.J. Colony No.1, Rajeev Nagar, Ram Rahim, Chowk, Bhalaswa Dairy, Delhi- 110042.

Sir,

Please refer to your letter No- Nil dated 29.10.2024 received in this department vide outdoor dairy no.9194 dated: 19.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. Pankaj Kr. Verma (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. There is two nos. of staircase is provided width of 1.30m & 1.10m from ground to second floors only against the requirement of 1.50m each from ground to terrace level for inspection of fire pump & ~~seen~~ overhead water tank.
2. Hose reel hose is provided but not functional and all nozzle is missing.
3. Terrace level fire pump required 450lpm but not conformity because terrace staircase is not provided.
4. Overhead fire water tank required 10,000ltr but not conformity because terrace staircase is not provided.
5. Exit signage not provided at strategic locations in the school building.
6. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director  
Ph: 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.

Handwritten signature and date 11/12