



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/26



No: F.6/DFS/MS/School/2024/WZ/ 826

Dated: 13/12/2024

To,

The Principal,
MCD Primary School,
Devaram Park, Tri Nagar,
Delhi-110035.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MCD Primary School located at Devaram Park, Tri Nagar, Delhi- 110035.

Sir,

This has reference to your letter no. 78 dated 29.11.2024 received through outdoor diary no. 9860 dated 03/12/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 09.12.2024 to see the to see the compliance of the requisite fire safety measures. Smt. Usha Devi (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and Two Upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Width of staircases found 1.27 m & 1.04 m against the required width of 1.50 m each.
2. First aid hose reel found provided but not functional.
3. Terrace level pump found provided but not functional.
4. Overhead tank of 2500 lts capacity is provided but not exclusively for fire fighting purpose.
5. Class rooms having more than 45 students shall have two numbers of exits.
6. Electrical meter and panel installed under the staircases have to be removed to a safer place or been segregated.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

He N
17/12/24

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.