

C-18



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
 आजादी का
 अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 817

Dated: 11/12/2024

To

The Principal,
 New Era School,
 261, Jamia Nagar, Noor Nagar Road,
 New Delhi-25.

Sub:- Regarding issuance of Fire Safety Certificate in respect of **New Era School** located at **261, Jamia Nagar, Noor Nagar Road, New Delhi-25.**

Sir,

With reference to the letter bearing outdoor diary no. 9470 dated 25.11.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 04.12.2024 in the presence of Mrs. Hina Adnan (Head Mistress) and it was observed that the school building is comprised of Ground + 1 upper floor. During inspection following shortcomings were observed:-

1. First Aid Hose Reel has not been provided.
2. Fire pump having capacity 450 LPM & head 40 m has not been provided.
3. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
4. Exit signage has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

06/12/24 e

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.