

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 8/5

Dated: 11/12_/2024

To

The Principal
Nigam PratibhaVidyalaya B-II,
B-Block, Jahangir Puri, Delhi-110033.

Sub: - Regarding renewal of fire safety certificate in r/o Nigam PratibhaVidyalaya B-II, (School ID No-1253006) located at B-Block, Mangal Bazar Road, Jahangir Puri, Delhi-110033. Sir,

Please refer to your letter No- Nil dated 05.11.2024 received in this department vide outdoor dairy no.8599 dated: 05.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor each. At the time of inspection Mr. Ravi Shankar (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1 Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours flithfully

:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.