

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/ 2698

Dated: 13/12/2024

To,

Dr. Namadhar Sharma(Director),
Premadhar Research Institute & Hospital,
Deep Vihar, Sector-24 Extn, Rohini,
Delhi-110042.

Sub:- Issuance of Fire Safety Certificate in r/o Premadhar Research Institute & Hospital, Deep Vihar, Sector-24 Extn, Rohini, Delhi-110042.

Sir,

Kindly refer to letter received in this department through outdoor diary no. 9330 dated 20.11.2024 on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 544 & 2494 dated 20.03.2023 & 11.11.2024 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 20.03.2023 & 11.11.2024 for further consideration in this matter.

Yours Faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

021
24

cmo

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2023/ 544

Dated: 20/03/2023

To,

Dr. Yogita Munjal (Deputy Director ISM),
Directorate of Ayush,
Government of NCT of Delhi,
Tibbha College Complex,
Karol Bagh,
New Delhi-110005. Y

Sub:- Issuance of Fire Safety Certificate for our r/o Premadhar Research Institute & Hospital, Deep Vihar, Sector-24 Extn, Rohini, Delhi-110042.

Sir,

This is in reference to your letter No. F.1(3)/Ayush/Misc/2020/510 dated 02.02.2023 received through outdoor diary no. 11173 dated 10.02.2023 on the subject cited above. In this regard it is to inform you that FSC under Rule 35 of DFS Rules-2010 is issued only for those premise which are referred by Building Authority/local authority as specified in section 2 (q) of DFS Act-2007 to this department.

In this regard you are advised to first apply with concern building sanctioning authority with a request to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS Rules-2010 on the said premise/building:

1. Sanctioned/Completion plans.
2. As built plans (Area, Floors, section & Elevation plans in a scale of 1:100) of the building through building/local authority & licensing authority/DGHS, if Sanction/Completion plans are not available.
3. Occupancy of each of floors as per clause 1.4.75 of UBBL-2016 and its initial operation date.

Yours faithfully


(Atul Gang)
DIRECTOR

Ph; 011-23414000

Copy to:-

1. The Deputy Commissioner, Narela Zone, North Delhi Municipal Corporation, Opp. Police Station, Narela, Delhi, 110040