



No. F6/DFS/MS/Hospital/NDZ/2024/ 671

Dated: 13/12/2024

To,

The Administrative Officer,
Red Cross General Maternity & Child Care Hospital,
Seemapuri, Delhi- 110095

Subject: - Regarding grant of Fire Safety Certificate in r/o Red Cross General Maternity & Child Care Hospital, Seemapuri, Delhi- 110095.

Sir,

This has a reference to your outdoor diary no. 9048 dated 14/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/12/2024 in the presence of Ms. Heena (Caretaker) and observed that building comprised of **Ground Plus two upper floors.**

Following shortcomings were observed during time of inspection:

1. Two staircases of width 1.2 meters each & 1.74 meter ramp are provided instead of required width of 2.0 meters each & 2.0 meters ramp respectively.
2. All Fire Extinguishers found empty.
3. First-Aid-Hose Reel provided but not functional.
4. Pumping arrangements one electric pump of 2280 LPM, one jockey pump of 180 LPM and one diesel pump of 2280 LPM fire pump provided but not functional.
5. Overhead water tank of capacity 5000 liters found removed.
6. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi -110092.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.