



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आपदापीडित
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2024/ BNET/137

Dated: 16/12/2024

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Garg Celebration (A Unit of Garg Enterprises) located at Property No. C – 24 & 25, First, Second floor, Acharya Niketan, Mayur Vihar Phase – I, Delhi - 110091.

Sir,

This has a reference to MHA application No. 2024111516822 dated 15/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 30/11/2024 in the presence of Mr. Jatin Garg (Owner) and observed that building comprised of **Ground + Mezzanine + 1st & 2nd floor (Banquet Hall running on 1st & 2nd Floor only)**

Following shortcomings were observed during time of inspection:

1. Fire Check doors found removed.
2. Door size of 1st Floor are 1.50 mtr. & 1.30 mtr. and 2nd Floor are 1.80 mtr. & 1.30 mtr. against requirement of 2 mtr. width at each floor.
3. First Aid Hose Reel & Internal Hydrant provided but found nonfunctional.
4. A Fire pump of 450 LPM provided but found nonfunctional.
5. Overhead water tank of 10,000 ltrs. provided against required capacity of 15,000 ltrs.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


13/12/2024
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Manager, M/s Garg Celebration (A Unit of Garg Enterprises) located at Property No. C – 24 & 25, First, Second floor, Acharya Niketan, Mayur Vihar Phase – I, Delhi - 110091.