

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2024/SZ/ 679

Dated: 17/12/2024

To

The Authorized Signatory,  
Hostel Building Institutional Complex,  
DG, s Residential, B-15, Qutab Institutional Area,  
South IIT Delhi

Sub:- Regarding issuance of Fire Safety Certificate in r/o Hostel Building (IIFT) Institutional Complex and DG,s Residential Bang low at B-15, Qutab Institutional Area, Delhi 110016

Sir,

This has reference to with letter received through Email dated 03/12/2024 on the subject above. In this connection, it is to inform you that the inspection of the premise was conducted by the officers from Delhi Fire Service on 12/12/2024 in the presence of Ms. Nalini Meshram (Assistant Registrar to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. One side of the building width is less than 06 mtr due to the drainage system.
2. Fire check door found removed in the building.
3. Sealing of Shafts not in conformity.
4. First aid hose reel provided but found not working.
5. Detection & alarming system is parsley provided.
6. Automatic sprinkler system not working.
7. Internal hydrant provided but found not working.
8. Electrical Fire Pump capacity 2400 LPM, Diesel Engine Pump 2400 LPM and Jockey Pump 180 LPM found removed.
9. Underground tank capacity 2, 00,000 ltrs found removed.
10. Exit signage found removed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 363 dated 27/06/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Building Department) HQ, Civic Centre, Minto Road, New Delhi 110002