

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 556

Dated 16/12/2024

To

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, PS Defence Colony  
New Delhi 110049.

**Sub:** Regarding issuance of fire safety certificate in r/o **M/s IVORYY** located at T-540,  
Panchshila Park, Malviya Nagar, New Delhi 110017

Sir,

This has reference to with **MCD Portal ID 2024112917441** dated **02/12/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.12.2024 in the presence of Mr. Ravinder (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed:

- 1 First aid hose reel provided but found not functional.
- 2 Internal hydrant provided but found not functional.
- 3 Fire fighting pump capacity 450 LPM provided but found not functional.
- 4 Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

all c