



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

2/08



No. F6/DFS/MS/2024/School/ 837

Dated: 19/12/2024

To

The Chairmen  
Maharaja Pratap Global School at J-Block,  
Gali No-1, Swaroop Nagar, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Maharaja Pratap Global School located at J-Block, Gali No-1, Swaroop Nagar, Delhi-110042.

Sir,

Please refer to your letter received through online e-mail dated: 09.12.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 10.12.2024 in the presence of Sh. Surjeet Singh (Chairmen) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/School/504 dated 07.08.2024 and status is as under: -

S No.	Shortcomings	Status
1.	Only one staircase is continues from ground to terrace level against the requirement of both staircases continues from ground to terrace level.	Not Complied
2.	All classroom doors size is 01m against the requirement of 1.20m.	Not Complied
3.	Fire extinguisher is not provided.	Complied
4.	First aid hose reel hose is not provided.	Complied
5.	Terrace level fire pump capacity of 450lpm is not provided.	Complied
6.	Terrace level fire fighting water tank capacity of 10,000ltr is not provided. (Provided but domestic use)	Not Complied
7.	Exit signage and floor signage not provided at strategic locations in the school building.	Not Complied

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Gang)  
Director

Ph: 011-23414000

Copy to:-

1. The Deputy Director of Education, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.