

2024

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 833

Dated: 18/12/2024

To,

The Manager,
Maharaja Pyare Lal International, School,
1228, Street No.19, Shyam Colony,
Budh Vihar, Phase-II,
Delhi-110086.

Sub: Issue of FSC in r/o Maharaja Pyare Lal International, School, 1228, Street No.19, Shyam Colony, Budh Vihar, Phase-II, Delhi-86.
Sir,

This is in reference to your letter No. nil dated 02.09.2024 received through outdoor diary no. 6029 dated 04.09.2024 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 29.11.2024, in presence of **Mr. Harsh Kumar Garg** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Accessible road on which building abuts is less than 6mtr.
2. Alternate Staircase of 1.50mtr ground to terrace level is not provided.
3. First Aid hose reel not provided.
4. Terrace Fire pump with capacity 450 LPM not provided.
5. An overhead water storage tank capacity of 10,000 ltr for firefighting is not provided.
6. Exit signage not provided.
7. Copy of approved/ as built plans & proof of year of construction school building may kindly be provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

o/c
my