



No. F6/DFS/MS/EH/NDZ/2024/ 555

Dated: 16/12/2024

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Mayurs Urban Spice located at B – 1, Main 100 Feeta Road, Chajjupur, Near Durgapuri, Shahdara, Delhi - 110094.

Sir,

This has a reference to MHA application No. 2024111516846 dated 16/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 11/12/2024 in the presence of Mr. Tarun (Owner) and observed that building comprised of Basement, Ground plus three upper floors only, **(Restaurants is running on ground floor of the building)**

Following shortcomings were observed during time of inspection:

1. First – Aid - Hose Reel provided but not functional.
2. MOEFA provided but not functional.
3. Internal Hydrants provided but not functional.
4. Terrace level fire pump capacity of 450 LPM provided but not functional.
5. Overhead tank of 3,000 liters capacity is provided against the requirement of 20,000 liters.
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Mr. Tarun (Manager), M/s Mayurs Urban Spice located at B – 1, Main 100 Feeta Road, Chajjupur, Near Durgapuri, Shahdara, Delhi - 110094.