



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/28



No. F6/DFS/MS/2024/School/ 827

Dated: 16/12/2024

To

The Principal,
M.C. Primary School,
Lal Bagh New-I & II, Azadpur, Delhi-33.

Sub: - Regarding grant of fire safety certificate in r/o M.C. Primary School (School I'd No-1253408-1253116) at Lal Bagh New-I & II, Azadpur, Delhi-110033

Sir,

Please refer to your letter no. nil dated 19.11.2024 received in this department vide outdoor dairy no9356 dated: 20.11.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 01.12.2024 in the presence of Sh. Subodh Kr. Singh (incharge) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2023/School/539 dated 10.11.2023 and status is as under: -

S No.	Shortcomings	Status
1.	The width of access road is less than 06m.	Not Complied
2.	The main gate width of 2.60m provided against the requirement of 4.50m.	Not Complied
3.	Only single staircase is provided at site width of 1.45m against the requirement of 1.50m.	Not Complied
4.	Fire extinguishers are not provided.	Complied
5.	Exit & floor signage's are not provided at strategic locations in the building.	Not Complied

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.