



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/School | 828

Dated: 16/12/2024

To

Sh. Narender Kumar Gaur,
Fire Officer, NDMC,
Mezzanine Floor, Sansad Marg,
Palika Kendra, New Delhi-110001

Sub: Regarding renewal of Fire Safety Certificate in r/o Navyug Senior Secondary School located at Lodhi Road, New Delhi-110003

Sir,

This has reference to the email received from Id. fo@ndmc.gov.in dated 20/11/2024. In this connection, the said premises was inspected by the officer concerned of this department on dated 06/12/2024 in the presence of Dr. Dinesh Madan (Principal) from fire & life safety point of view. During course of inspection, the following shortcomings were observed.

1. First-aid hose reels found non-functional.
2. Terrace level fire pumps found non-functional.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in this regard. The occupancy of the building/premises in the absence of functional fire safety measures shall be at risk and liability of the management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Principal, Navyug Senior Secondary School located at Lodhi Road, New Delhi-110003