



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2024/ 725

Dated: 3/12/2024

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Park View Guest House, Plot No. 29 (Old) New No. A - 96, Ghazipur Village, Delhi - 110096.

Sir,

This has a reference to MHA application No. 2024111416808 dated 14/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/11/2024 in the presence of Mr. Tarun (Owner) and observed that building comprised of **Ground Plus three Upper Floors**, Ground floor – (Reception), 1st floor - (05 guest rooms), Second floor - (05 guest rooms) & third floor- (05 guest rooms), total 15 guest rooms.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel at each floors provided but not functional.
2. Terrace level fire pump capacity of 450 LPM not provided.
3. Overhead tank of capacity 5,000 liters not provided.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Mr. Tarun (Owner), M/s Park View Guest House, Plot No. 29 (Old) New No. A - 96, Ghazipur Village, Delhi - 110096.