



75  
Azadi Ka  
Amrit Mahotsav

c/94

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2024/SZ/ 733

Dated: 16/12/2024

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Kings Inn Guest House located at Property. No. 14A/7, WEA Karol Bagh, New Delhi-110005**

Sir,

This has reference to online portal ID No. 2024120317577 dated 03/12/2024. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 06/12/2024 to verify status of the fire & life safety arrangements provided in the presence of Sh. Raj Kumar (Manager). During the inspection, the shortcomings observed are as below.

1. Basement could not be checked as it was kept closed/locked.
2. Smoke management system in basement could not be checked due to the reason mentioned at para 1 above.
3. Terrace fire pump was not on auto mode.
4. Lift signage found removed.
5. Temporary construction found on terrace.
6. Terrace door opening is inwards against required outwards opening.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Parminder Singh, M/s Kings Inn Guest House located at Property. No. 14A/7, WEA Karol Bagh, New Delhi-110005