



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/64

No. F.6/DFS/MS/BP/2024/ College | 371

Dated: 25/11/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Sub: Rejection of building plans from fire safety point of view in r/o Educational Building
Plot no. 01, Delhi University North Campus, Delhi-110007.


Sir,

With reference to your request ID no. 10119678 dated 14.11.2024 on the subject cited above; it is informed that the referred online building plans in respect of proposed construction of Educational Building at Plot no. 01, Delhi University North Campus, Delhi-110007 were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Fire Control Room is not proposed as per UBBL-2016/NBC-2016, Part-IV.
2. Fire tower is not proposed as per UBBL-2016/NBC-2016, Part-IV.
3. Fire pump room is not proposed as per UBBL-2016/ NBC-2016, Part-IV.
4. Fire tender movement path/road is not proposed as per clause 8.2 of UBBL-2016/ NBC-2016.
5. Waiting area is not acceptable in the corridor.
6. The information provided in CAF are not in congruous with the building plans submitted.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,


(Atul Singh)

Director

