## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Ca

No. F.6 /DFS/MS/BP/2024/ 664

Dated: 11 12 2024

To,

Dr. Sandeep Kumar Agarwal Medical Superintendent -Nursing Home DGHS, 3<sup>rd</sup> Floor, Delhi Government Dispensary Building, S-1, School Block, Shakarpur, Delhi-110092

Sub:

Clearance from fire safety point of view in r/o Plot No. 3 or 4, Block H, Bali Nagar, New Delhi-110015

Sir,

Please refer your F.24/New/West/DGHS/NHC/2024/2110 dated 03/12/24 on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that the shortcoming issued vide letter No. F.6/DFS/MS/BP/2024/366 dated 28/06/2024 have not yet been complied.

Accordingly, the case is hereby rejected.

Yours faithfully,

(Atur Garg) Director

011-23414000

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2024/ 3 ( (

Dated: 28 06/2024

To,

The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9th floor, Civic Centre, Minto Road, New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 3 or 4, Block H
,Bali Nagar, New Delhi-110015

Sir,

Please refer your online request ID No.-10118580 dated 20/06/2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of construction of institutional (Hospital) building at Plot No. – 3&4, Block H, Bali Nagar, New Delhi-110015.

Following shortcoming is observed:

- 1. Staircase is not segregated at ground floor as per clause 7.11(t) of UBBL-16.
- 2. Exit is passing through another unit which is not allowed as per clause 7.5.10 of UBBL 2016.
- Corridors/passageway is not proposed as per clause7.11.2(e) of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,

11-23414000

work!