



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 836

Dated: 19/12/2024

To

The Principal
Govt. Sarvodaya Kanya Vidyalaya,
At Malka Ganj, Delhi-110007.

Sub: - Regarding renewal of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya (School ID. No-1309025) located at Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter received through online e-mail dated: 09.12.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 14.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 blocks, one block comprised of ground + first floor & one block comprised of ground + 03 upper floors. At the time of inspection Sh. Vinay Kr. Panday (Guard) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire Extinguisher is provided but not functional.
2. Hose reel hose is provided but not functional.
3. Internal hydrant is provided but not functional.
4. Fire pump 450lpm is provided but not functional.
5. Exit signage's found removed at some places.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director
Ph: 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

17/12/24