



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2024/ 683

Dated: 18/12/2024

To,

Sh. K. R. Chawla,  
Dy. Drugs Controller/Licensing Authority,  
Govt. of NCT of Delhi, Drugs Control Department,  
F-17, Karkardooma Delhi

Sub:- Issuance of No Objection Certificate (NOC) from fire safety point of view in r/o M/s Shama Cosmetics at Plot No. 228, Pocket-E, Sector-4, Bawana Industrial Area, Delhi-110039.

Sir,

With reference to letter no. F.144/NW/24/CM/3074 dated 06.11.2024 on the subject cited above, it is informed that the referred building plans in respect of M/s Shama Cosmetics at Plot No. 228, Pocket-E, Sector-4, Bawana Industrial Area, Delhi-110039 were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Building plans shall be submitted as per clause 2.0.4 of the UBBL-2016/ NBC-2016, Part-IV.
2. These building plans shall also include year of construction, change of occupancy/use as allowed by MCD/local authority and shall be duly marked with fire and life safety systems as per NBC-2016, Part-IV.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,

(Dr. S. K. Tomar)

Dy. Chief Fire Officer

Copy to:-

1. M/s Shama Cosmetics at Plot No. 228, Pocket-E, Sector-4, Bawana Industrial Area, Delhi-110039:- with request to submit the plans as stated through local/above mentioned statutory authority.