



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/176

No. F.6/DFS/MS/School/2024/SZ/ 689

Dated: 23/12 /2024

To

Sh. Rajesh Kumar (Manager),
Sri Sathya Sai Primary School,
(Unit of Sri Sathya Sai Central Trust)
Pragati Vihar, Bhisma Pitamah Marg,
New Delhi-110003

Sub: Regarding issuance of Fire Safety Certificate in r/o Sri Sathya Sai Primary School located at Pragati Vihar, Bhisma Pitamah Marg, New Delhi-110003

Sir,

This has reference to your letter No. 01/2024-2025 dated 22/11/2024, received through outdoor diary No. 9874 dated 03/12/2024. In this connection, the premise was inspected by the officer concerned of this department on 11/12/2024 from fire & life safety point of view in your presence. During the course of inspection, the shortcomings observed are as below.

1. Two staircases of 1.35m width & 0.70m width (Rear side, landing between 1st & 2nd floor) found provided. The width of main staircase serving each floor found 1.35m against required width of 1.5m.
2. Exit signages found not found provided.

In view of the above, application for issuance of Fire Safety Certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054