

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2024/SZ/ 2756

Dated: 19/12/2024

To

The Authorized Signatory,
Storage Building at Khasra No 875/2,
Mahipalpur, K-2 Block, New Delhi-110037.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Storage building at Khasra No 875/2, Mahipalpur, K-2 Block, New Delhi-110037.

Sir,

This has reference to with letter received through outdoor diary no 7833 dated 15/10/2024 on the subject above. In this connection, it is to inform you that the inspection of the premise was conducted by the officer from Delhi Fire Service on 17/12/2024 in the presence of Mr. Amandeep to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. First aid hose reel provided but found not working.
2. Automatic sprinkler system not working.
3. Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM provided but found not working.
4. Terrace level fire fighting pumps capacity 450 LPM provided but found not working.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Building Department) MCD Near Dhansa Bus Stand Najafgarh, New Delhi 110043