

c/68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 732

Dated:- 16.12.2024

To,

The Manager
M/s Yes Sir guest house
T-419/5076, General Market,
Main Bazar, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Yes Sir guest house. T-419/5076, General Market Main Bazar Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024112117108 dated 21/11/2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 09/12/2024 in the presence of Mr. Mahesh Kumar and following shortcomings were observed: -

1. Hose reel & pump found nonfunctional.
2. MOEFA found nonfunctional.
3. PA system not provided.
4. Pump was not provided with auto mode provision facility.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service
12/12/24

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.