

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2024/SZ/ 690

Dated: 24/12 /2024

To,

Dy. Chief Architect,  
DMRC, Metro Bhawan  
Fire Brigade Lane,  
Barakhamba Road, New Delhi-110001.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Ahir Enterprises for CPD-06R Shop No 1, PD Area at Chattarpur Metro Station, Delhi.

Sir,

This has reference to your letter no. DMRC/FIRE/172/2024/11/398 dated 12/11/2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 18/12/2024 in presence of Mr. Ravinder Kumar, Fire Inspector to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There are two staircases having width of 1 mtr each against the required width of 1.50 mtr each.
2. The alternative exit door found closed/ encroached.
3. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE