



75
Azadi Ka
Amrit Mahotsav

C88

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2024/SZ/ 742

Dated: 20/12/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Elegant International (Guest House) located at Property. No. 6/28, WEA Karol Bagh, New Delhi-110005

Sir,

This has reference to online portal ID No. 2024121117894 dated 11/12/2024. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 16/12/2024 to verify status of the fire & life safety arrangements in the presence of Sh. Ajay Tomer (Manager). During course of inspection, the shortcomings observed are as below.

1. First-aid hose reel provided found non-functional.
2. Automatic fire detection system found non-functional.
3. Terrace fire pump found non-functional.
4. Fireman lift grounding switch & signage found removed.
5. Temporary structure on terrace being used for office purpose.
6. Waste material stored at terrace posed fire hazard.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Anil Kumar Vachhar M/s Elegant International (Guest House) located at Property. No. 6/28, WEA Karol Bagh, New Delhi-110005