

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 740  
To

Dated: 19/12/2024

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Hotel Pitrashish Pride located at , Khasra  
No-98, Kapashera, New Delhi- 110037

Sir,

This has reference with **MCD Portal ID 2024110716534 dated 11/12/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 16/12/2024 in the presence of Mr. Sharad to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Fire check door not provided in rear side in the building.
2. First aid hose reel provided but found not working.
3. Automatic sprinkler system provided but found not working.
4. Electrical Fire Pump capacity 1620 LPM, Diesel Engine Pump 1620 LPM and Jockey Pump 180 LPM provided but found not working.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

om c