



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/66

7/12  
आपदा निवारण  
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2024/ 745

Dated: 24/12/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Ref: elt.mcdonline application no. 2024112317231

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Karma Durga Guest House located at T-316, General Market, Pahar Ganj, New Delhi-13.

Sir,

With reference to the elt.mcdonline application no. 2024112317231 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on 13.12.2024 in the presence of Mr. Javed (Manager) and following shortcomings were observed at the time of inspection.

1. Hose reel found non functional.
2. Fire pump found non functional.
3. Guest house was also found running at 3<sup>rd</sup>, 4<sup>th</sup> & 5<sup>th</sup> floor though owner has submitted an affidavit dated 22.11.2019 not to use any floor above 3<sup>rd</sup> floor. The same shall be closed/sealed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

**Copy to :-**

1. The Executive Engineer (Bldg.), MCD, 9<sup>th</sup> Floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002. To verify the height of the building under intimation to this department.