



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/College | 387

Dated: 23/12/2024

To

Sh. Ranu Kumar (Admin Officer),
Maitreyi College, University of Delhi,
Bapu Dham, Chanakya Puri,
New Delhi-110021

Sub: Regarding renewal of Fire Safety Certificate in r/o "New Science Block" at Maitreyi College complex" Bapu Dham Chanakya Puri, New Delhi-110021

Sir,

This has reference to your email Id. ao@maitreyi.du.ac.in dated 19/11/2024, on the subject above. In this connection, the premise was visited by the officer concerned officer of this department on dated 10/12/2024 with a view to verify the status of fire and life arrangements in your presence. During course of inspection, the shortcomings observed are as below.

1. Escape route/corridor found encroached with iron almirahs at 1st floor.
2. First-Aid hose reels found non-functional.
3. Terrace fire pump was not on auto mode.
4. Exit signage found removed at some locations.
5. Lift signage found removed.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises/building in the absence of requisite fire & life safety arrangements shall be at the risk and liability of the college management.

Yours faithfully,

(ATEL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Executive Engineer (Bldg.), New Delhi Municipal Council, Sansad Marg, Palika Kendra, New Delhi-110001