



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2024/SZ/ 741

Dated: 19 / 12 / 2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o "The Spot Guest House" located at Property. No. 867-868, Gali Chandiwali, Main Bazar, Pahar Ganj, New Delhi-110055

Sir,

This has reference to online portal ID No. 2024121017847 dated 10/12/2024. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 13/12/2024 to verify status of the fire & life safety arrangements in the presence of Sh. Himanshu Katyal (Owner). During the inspection, the shortcomings observed are as below.

1. Basement could not be checked as it was kept closed/locked.
2. Automatic fire detection system found non-functional.
3. Exit signages found removed at some location.
4. Loose hanging wires found near electrical panel.
5. Waste material stored at terrace.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL DARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Ashok Kumar Katyal, "The Spot Guest House" located at Property. No. 867-868, Gali Chandiwali, Main Bazar, Pahar Ganj, New Delhi-110055