



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/61

No. F6/DFS/MS/2024/School/ 841

Dated: 24/12/2024

To,  
The Principal,  
Sarvodaya Co-ed Vidyalaya No-1  
At Shakti Nagar, Delhi-110007.

**Sub:-** Regarding renewal of fire safety certificate in r/o Sarvodaya Co-ed Vidyalaya No-1, (School ID No-1207037) located at Shakti Nagar, Delhi-110007.

Sir,  
Please refer to your letter no- SV/CO-ED/SN1/2024/784 Dated 29.11.2024 received in this department vide outdoor dairy no-10037 dated 06.12.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 18.12.2024 in the presence of Sh. Rajiv Ranjan (Estate Manager) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2023/School/481 dated 30.07.2024 and status is as under: -

S No.	Shortcomings	Status
1.	Hose reel hose provided but not functional and some nozzles found missing.	Not Complied
2.	Terrace level fire pump capacity of 450lpm each provided but found not functional.	Not Complied
3.	Exit and floor signage's found removed at strategic locations in the school building	Not Complied
4.	Inspection ladder for terrace level fire water tank is not provided.	Not Complied
5.	Electrical panel below in staircase needs to be removed/shifted in a safer place.	Not Complied

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi -110054.

20/12/24