

2597

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2024/ 695

Dated 18/12/2024

To,

The Assistant Engineer (E)-II,
R.M.L. Elect. Division, CPWD,
Dr. R.M.L. Hospital, New Delhi.

Sub: Regarding issuance of fire NOC of Dharamshala Building at Dr. RML Hospital, New Delhi.

Sir,

This has reference to your AE (E)-II/Dr.R.M.L/E.D/2024-25/207 dated 29.10.24, on the subject cited above, it is to inform that the site was inspected by the officer concerned of this department on 18/12/24 in the presence of Mr. Mohit (J.E) and the following shortcomings were observed: -

1. Corridor /passage way found blocked /encroached by dumping of waste material.
2. PA System found removed.
3. Exit signage found removed.
4. Pump is not provided with auto provision.
5. Stand by power supply not provided.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Atul Gang)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.