



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/693

Dated: 26/12/2024

To

Sh. Manoj Kumar (ASO),
Administrative Block
AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Geriatrics Block (National Center for aging),
Masjid Moth, AIIMS, Ansari Nagar, New Delhi-110029**

Sir,

This has reference to the email received from Id. manojkmr@aiims.gov.in dated 01/11/2024, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 17/12/2024 in the presence of Sh. Sailesh Kumar (ASO/Fire) & Sh. Harsh Tiwari (JE/Elect). The shortcomings observed are as below.

1. Electrical shaft was not sealed properly.
2. Water curtain found non-functional.
3. Smoke management system not found integrated with MCPs/Detection system.
4. Automatic fire/heat detectors found non-functional/defective at some locations as indicated during inspection.
5. Hose box on terrace found empty i.e. without branch & hoses.
6. Standby pump was not on auto mode.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the premises/building in the absence of requisite functional fire safety arrangements, shall be at the risk and liability of the management.

Yours faithfully,


(ATUL GARG)
Director
Delhi Fire Service

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029