

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2024/ 844

Dated: 27 12 2024

To,

The Principal, Govt. Sarvodaya Kanya Vidyalaya (ID-1617036), Amalwas, Jwalapuri, Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya, located at Amalwas, Jwalapuri, Delhi-110041.

Sir,

Please refer to your email dated 27/11/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 19/12/2024 in the presence of Sh. Satender Singh (Estate Manager). During inspection, it has been observed that the school building is comprised of New Block – Ground + 03 Upper Floors. However, the following shortcoming has been observed:-

- 1. First aid hose reels found non-functional.
- 2. Terrace pump of 450 lpm found non-functional.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.