

C/65

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2024/ 845

Dated: 27 /12/2024

To

The Principal,  
R.M. Arya Girls Sr. Sec. School  
Behind Madhya Pradesh  
Emporium, Baba Khark Singh Marg,  
Raja Bazar, New Delhi

**Sub: Regarding issuing of FSC in r/o R.M. Arya Girls Sr. Sec. School at Behind Madhya Pradesh Emporium, Baba Khark Singh Marg, Raja Bazar, New Delhi.**

Sir,

This has reference to your letter no. RMAS/2024-25/meis dated 02.12.2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 18.12.2024 in the presence of Smt. Preeti Mehta and the following shortcomings were observed.

1. Hose reel found nonfunctional.
2. Terrace pump found nonfunctional

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.