



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/NDZ/2024/ 700

Dated: 31/12/2024

To,

Sr. DGM/E/UD,
DMRC, Metro Bhawan, Barakhamba Lane,
Connaught Place, New Delhi- 110001.

Subject: - Regarding grant of Fire Safety Certificate in r/o Children homes for girls located at Dilshad Garden, Delhi - 110094

Sir,

This has a reference to your letter no. DMRC/E/UD/Sr.DGM/ Dilshad Garden/2024/ L3192 dated 03/09/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 16/12/2024 in the presence of Mr. and observed that building comprised of Basement, Ground plus two upper floors only

Following shortcomings were observed during time of inspection:

1. MOEFA is not provided.
2. Sprinkler system required in all building is not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
d/cat

Copy to:-

1. The Chief Architect, DMRC, Metro Bhawan, Barakhamba Lane, Connaught Place, New Delhi- 110001.