

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2024/ 702

Dated 3.1.2/2024

To,

The Assistant Engineer (E)-II,
R.M.L. Elect. Division, CPWD,
Dr. R.M.L. Hospital, New Delhi.

Sub: Regarding issuance of fire NOC of Old Emergency block at Dr. R.M.L. Hospital, New Delhi.

Sir,

This has reference to your AE (E)-II/Dr.RML/Hosp/E.D/2024-25/214 dated 18.11.2024, on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 16/12/24 in the presence of Mr. Mohit (J.E) & Sh. Omprakash (AE) and the following shortcomings were observed: -

1. MOEFA found nonfunctional.
2. Exit signage found inadequate.
3. Hanging electric wire required to be in cable trench.
4. Over head tank of 10,000 liter is not provided.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.