

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2024/ 699

Dated: 31 /12/2024

To

The Authorized Signatory,  
Ram Service Station, Opp. NSCI,  
Mathura Road, New Delhi.

**Sub:- Regarding renewal of fire safety certificate in r/o Ram Service Station, at opp. NSCI, Mathura Road, New Delhi.**

Sir,

This has reference to your letter no. NIL dated 25.11.2024, on the subject cited above in this regard, it is to inform you that the site was inspected by the officers concerned of this department on 20/12/2024 in the presence of Mr. Ravinder Sharma and the following shortcomings were observed:-

1. Foam Trolley of 20 liter is not provided.
2. No Smoking board of English & Hindi is not provided.
3. Further, CNG facility is also added at the existing petrol pump, hence building plans along with duly marked fire fighting arrangements provided for CNG is also required to be submitted through licensing authority concerned.

In view of above case is rejected with a request to rectify the above shortcomings and forward the case through licensing authority concerned at the earliest for further consideration in the matter.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service  
36/12