



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75
आज़ादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / CGHS/2024/ 691

Dated: 24/12/2024

To,

The Dy. Director (L&I) Bldg.,
Delhi Development Authority,
Vikas Sadan, INA,
New Delh-110023.

**Sub: Online building plans belonging to Union Rehabilitation Employees CGHS Ltd.
at Plot No. 7C, Sector-23, Dwarka, New Delhi for addition/alteration.**

Sir,

Please refer your online file No. DW23P/0044/2024 dated 02.12.2024 on the subject cited above. In this connection it is to inform you that the officer concerned of Delhi Fire Service inspected the aforesaid CGHS and noticed following deficiencies:

1. Width of staircases found varied form 120 to m 123 cm.
2. The width of internal road is varied from 5.5 m to 6.0 m.

Therefore, the proposal is rejected.

Yours faithfully

(ATUL GARG)
DIRECTOR

Ph. 011-23414000