



No. F6/DFS/MS/NDZ/2024/ 70)

Dated: 31/12/2024

To,

The Executive Engineer (Elect)-II/SSZ,
2nd Floor, Technical Laboratory,
Delhi-110096.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Multilevel Car Parking cum commercial building located at Ward No. 229 AC-60, Krishana Nagar, Delhi-110031.

Sir,

This has a reference to Email dated 19/11/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 16/12/2024 in the presence of Mr. Aquib A.E. (Electrical) & Mr. Diwakar Sharma (Electrician) MCD and observed that building comprised of **Two Basement, ground plus six upper floors.**

Following shortcomings were observed during time of inspection:

1. All fire extinguishers found empty.
2. First-Aid-Hose Reel at each floors provided but not functionable.
3. Automatic fire detection and alarming system provided but not functionable.
4. MOEFA provided but not functionable.
5. Public address systems provided but not functionable.
6. Automatic sprinkler system provided not functionable.
7. Internal hydrants not functionable.
8. Yard hydrants not functionabel
9. Ground level fire pump capacity of 2280 LPM provided but not functionable.
10. Terrace level fire pump capacity of 450 LPM provided but not functionable.
11. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Commissioner (MCD), 419, FIE, Patparganj Industrial Area, Delhi-110092.