

C/09

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2024/ 851
To

Dated: 30/ 12 /2024

The Principal,
Aminia Muslim Girls School,
2075, 2079, Ahata Kale Qasim Jaan,
Ballimaran Road, Chandni Chowk, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Aminia Muslim Girls School at 2075, 2079, Ahata Kale Qasim Jaan, Ballimaran Road, Chandni Chowk, Delhi - 06.

Sir,

This has reference to letter outdoor diary no. 9818 dated 02.12.2024 & 10485 dated 18.12.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 16.12.2024 in the presence of Mohd. Salman (Manager) and observed that the building is comprised of basement + ground + 03 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/NDZ/School/2024/785 dated 25.11.2024 except following which still exists.

1. Road width is less than required width 06 meter. Hence building is not accessible to fire engine.

In view of the above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service o/c

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

10
20/12
26/12