

c/28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2024/ 848

Dated: 30 /12/2024

To

The Principal,  
City Modern School,  
C-5/86, Gali No. 2, Sadatpur Extension, Delhi-94

**Sub: Regarding Fire Safety Certificate in r/o City Modern School located at C-5/86, Gali No. 2, Sadatpur Ext., Delhi-94.**

Sir,

This has reference to outdoor dairy No. 10347 dated 16/12/2024 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 23/12/2024 in the presence of Mr. Ashwani Kumar and observed that at present school is Ground + 03 upper floors only. Fire safety measures were checked as per the rules and following shortcomings were observed.

1. Over head tank of 5000 lts capacity is provided against required capacity of 10,000 lts.
2. Exit sign. is removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-53.

e/CA