

c/05

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/SZ/2024/ 567

Dated: 27/12/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Coffee House (A unit of Muhavra Enterprises Pvt. Ltd.) at Shop No. 8 & 9, Ground Floor, Pocket - 8, Sector - C, Vasant Kunj, Delhi - 110070.

Sir,

This has reference to online application ID No. 2024112917434 dated 05.12.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.12.2024 in presence of Mr. Nganing Shing (Manager) and it was observed that building is comprised of ground floor only. During inspection, following shortcomings were observed:

1. 01 no. of door is provided having width of 1.50 m against the requirement of 02 nos. width of 1.5 m each.
2. First aid hose reel not provided.
3. Internal hydrant (down comer) not provided.
4. Fire pump of capacity 450 LPM not provided.
5. Over head water storage tank of 20,000 liters capacity is required exclusively for firefighting.
6. Exit signages are not adequately provided.
7. Plan of the restaurant duly signed by architect and owner/ occupier, not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Anil Garg)
Director
Delhi Fire Service o/c
Tel: 01123414000
e 24/12

Copy to:-

The Manager,
M/s Coffee House (A unit of Muhavra Enterprises Pvt. Ltd.) at Shop No. 8 & 9, Ground Floor, Pocket
- 8, Sector - C, Vasant Kunj, Delhi - 110070..