

c/08



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/6
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 849

Dated: 30/12/2024

To

The Manager,
Ken Public School,
B-18, Main Kalindi Kunj Road,
Jaitpur Extension Part-II, Badarpur, New Delhi-44

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Ken Public School** located at **B-18, Main Kalindi Kunj Road, Jaitpur Extension Part-II, Badarpur, New Delhi-44.**

Sir,

With reference to your email dated 11.12.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.12.2024 in the presence of Mr. Gaurav Sharma (Manager) and it was observed that the school building is comprised of Ground + 01 upper floor. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters width each has not been provided.
2. Width of corridor 1.50 meters has not been provided.
3. First aid hose reel has not been provided at each floor.
4. Fire pump of 450 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
6. Exit signage has not been provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.


Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.


20/12/24 e