

466

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/02

Dated:-01/01/2025

To

The Manager
M/s Mahajan Palace 10830,
Jhandewalan Road, Chowk Motia Khan,
Karol Bagh, New Delhi.

Sub: Regarding issuance of FSC in r/o M/s Mahajan Palace located at 10830, Jhandewalan Road, Chowk Motia Khan, Karol Bagh, New Delhi.


Sir,

This has reference to online id no. 202412178080 dated 17.12.2024, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 27/12/24 in the presence of **Mr. Pawan kumar Mahajan (Owner)** and following shortcomings were observed:-

1. Hose reel found nonfunctional.
2. Co detectors found nonfunctional.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,


(Anil Garg)
DIRECTOR
Delhi Fire Service
27/12/24

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.